



Akkreditierte Prüf- und Inspektionsstelle – gbd Lab GmbH

Test report

Airborne sound insulation to EN ISO 10140

Client	C.R. Laurence Co., Inc.	Address	2503 E. Vernon Avenue Los Angeles, CA 90058-1826
---------------	-------------------------	----------------	---

Designation	CRL FALLBROOK SERIES	Identification	CRL FALLBROOK XL
Frame material	Aluminum	Dimensions	Width 120 1/8 Height 105 7/8

Product standard	Windows and Doors	EN 14351-1	
Rating test element	Rating of sound insulation in buildings and of building elements	EN ISO 717-1 R_w (C; C _{tr}) [dB]	ASTM E413-10 STC* [dB]
	Glass construction fixed part 1/2" laminated safety glass with 0.03" sound insulation interlayer 3/16" CRL Edgetech Super Spacer 11/32" laminated safety glass with 0.03" sound insulation interlayer Glassdoor: 1/2" laminated safety glass with 0.03" sound insulation interlayer	37 (-1;-2)	37
	Glass construction fixed part 1/2" laminated safety glass with 0.03" sound insulation interlayer 3/16" CRL Edgetech Super Spacer 11/32" laminated safety glass with 0.03" sound insulation interlayer Wooden sound insulation door (42 dB)	40 (-1;-4)	40
	Glass construction fixed part 1/2" laminated safety glass with 0.03" sound insulation interlayer 3/16" CRL Edgetech Super Spacer 11/32" laminated safety glass with 0.03" sound insulation interlayer	42 (-1;-4)	42

* not in the accredited range

This cover can be used as an edited version. We reserve all rights in this document and in the information contained therein.

Akkreditierte Prüf- und Inspektionsstelle / Accredited Testing and Inspection Center – gbd Lab GmbH FN 295310f
Steinebach 13a A-6850 Dornbirn T +43 5572 394830-0 F +43 5572 394830-39 office.lab@gbd.at www.gbd.at

gbu Lab GmbH, Steinebach 13a
6850 Dornbirn, Austria
www.gbd.group