

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513779A

Manufacturer: C.R. Laurence Co., Inc.
2503 E. Vernon Ave.
Los Angeles, CA 90058

Product Line: Monterey S55 Out-Swing Aluminum Bi-Fold Door W/Raised Track

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02945 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: E1588.01-301-47 signed by Jarod S. Hardman.
Architectural Testing, Inc. Lake Forest, CA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 20.05 psf
Water penetration resistance 3.13psf
3. Anchor calculations, report number 513779-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 20.0 psf
- Panel size: 37" x 96"
- Approved Configurations: 1L, 1R, 2L, 2R, 3L, 3R, 4L, 4R, 2L2R, 5L, 5R, 6L, 6R, 7L, 7R, 8L and 8R
- Units must be glazed per ASTM E1300, with safety glass.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be aluminum 6063-T6.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02945, Revision A.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

