

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515335

Manufacturer: C.R. Laurence Co., Inc.
2503 E. Vernon Ave,
Los Angeles, CA 90058

Product Line: Entice HP+ Double Side Hinged Door, Non-Impact

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04020, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: Q5257.02-303-47 signed and sealed by Tyler Westerling P.E.
Intertek, Lake Forest, CA
ASTM E330
Design pressure: ± 30.08 psf
3. Anchor calculations with comparative analysis, report number 515335-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to installation drawing
- Unit size: Refer to installation drawing
- Units must be glazed per ASTM E1300, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T6 with Steel Cladding.
- This system was not tested for water penetration infiltration and must be installed in locations where water penetration resistance is not required.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-04020.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

