# VALENTIN ENGINEERING LTD

## 11 Camwood Crescent

### North York, Ontario

**M3A 3L3** 

Phone: (416) 444-0001 Fax: (416) 445-8333

C. R. Laurence Canada

July 4, 2014

65 Tigi Court

Concord, Ontario

L4K 5E4

Att: Ron Rehel

C. R. Laurence – Railing Base Shoes

Page 1 of 2

For compliance to the 2012 Ontario Building Code.

types B5S, B5T, B6S, B7S, L56S, L21S and L25S for compliance to the 2010 National Building Code and the 2012 Ontario Building Code. We have reviewed the structural design of the C. R. Laurence railing base shoe

### Design Loads

- Design loads are based on combination loading 1.4W + 0.5L or 1.5L + 0.4Wwhichever produces the higher loading.
- 3 Lateral Guard Point Load = 1.0 kN (225 lbs) applied at 1067mm (42") above the finished floor.
- Ç above the finished floor. Lateral Guard Line Load = 0.75 kN/m (51.4 lbs/ft) applied at 1067mm (42")
- 4 Lateral Guard Concentrated Load = 0.5 kN (112.5 lbs) applied over a 100mm x 100mm (3.9"x 3.9") area anywhere within the guard.
- Ċ load does not act simultaneously with any lateral loads. Vertical Guard Line Load = 1.5 kN/m (102.9 lbs/ft) applied on the top rail. This
- 6. Wind load for this analysis taken as 1.0 kPa (20.9 pst)

### **Material Specifications**

- All aluminum members to be alloy 6063-T52 or better and comply with CAN3-S157 latest edition.
- All glass is to be in compliance to CAN/CGSB-12.20-M89
- ယ All tempered and laminated glass to comply with CAN/CGSB-12.1 and 12.2 latest edition.
- In Ontario all glass must also conform to building code SB-13
- For exterior applications, all fasteners are to be stainless steel.

For compliance to the 2012 Ontario Building Code

- Glass design is based on a maximum glass height of 1067mm (42").
- heat-strengthened and laminated. As per SB-13, glass located within 51mm (2") of the balcony floor edge is to be
- floor edge is to be tempered and heat-soaked As per SB-13, glass located between 51mm (2") and 152mm (6") of the balcony
- 4. per CAN/CGSB-12.20-M89 section A5.2. Where glass edges are vulnerable to hard body impact, they are to be protected as
- Ç protected by a horizontal member as per CAN/CGSB-12.20-M89 section A5.1. Glass design is to assume each alternate glass pane has failed. All glass is to be

### Contractor's Responsibilities

- engineering design is required. maximum 1.0 kPa (20.9 psf) design load. For higher wind loads additional The contractor is to confirm that the wind loads for the project do not exceed the
- The contractor is to ensure the glass used complies with SB-13.
- 32 52 attached, is structurally adequate for support the applied loading The contractor is to confirm that the structure, to which the railing will be
- 4. with the local building department. The contractor is to confirm that all climability issues are addressed in accordance
- S Railing design is to assume each alternate glass pane has failed. All glass is to be protected by a horizontal member as per CAN/CGSB-12.20-M89 section A5.1.
- 6 shoe to the structure. resistance, tension resistance etc... must all be reviewed as per the manufacturer's The contractor is to ensure that the correct fasteners are utilized to secure the base Fastener edge distances, spacing, pull-out resistance, shear
- Railing installation is to be inspected as required by the local building department.

the railing loading, and the glass type required and the type of fasteners required to secure the railing to the structure. The use of structurally inadequate glazing, inadequate engineer to confirm wind loads for the region, structural adequacy of structure to accept pressure of 1.0 kPA (20.9 psf). Each individual project will still require a professional meet the load requirements set out in the 2012 Ontario Building Code, up to a wind Note: The above letter certifies that the railing base shoes are structurally adequate to building support structure design can all result in failure of the railing system connection of the railing posts to the structure and/or a structurally inadequate base

Sincerely Yours

Valentin Brinovec, P.Eng

B CHINCE OF OMINATIO PROFESSION V. BRINOVEC