

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC.**
6107 INDUSTRIAL WAY, HOUSTON, TX 77011

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 & v5.0 ID+C, BD+C
TVOC Emissions at 14-days
US-CHPS 2020 Criteria (R2022) EQ C6.1.1
low-emitting materials
low-emitting materials
0.5 mg/m³ or less
adhesives & sealants

Certified Products: Group 12 (Mirror Mastics): Gunther Premier Plus Mirror Mastic**, BE 220.

** Product tested as representative exemplar of products listed above.

Test Date: December 23, 2025 Report No.: 2500717 Certificate No.: MAS2500717-08R1

Valid: December 2025 to December 2026



Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>